

Copied from Email

Ms. West,

BNSF has reviewed the proposed development known as Jellystone at Larkspur. BNSF has a couple of comments, BNSF may have a couple more comments on the crossing to follow.

1. Any utility crossings across BNSF property will need to be permitted through BNSF/Jones Lang Lasalle.
2. ROE for construction will need to be permitted through BNSF/Jones Lang Lasalle. No modifications shall be made to BNSF property without approval.
3. Detention pond overflows onto BNSF property will need to have associated H&H reports to show same or reduced flow as what currently comes onto BNSF property.
4. Improvements shall provide fence at ROW line for the extent of the project.

Thanks,

Rafer Nichols

Project Engineer

BNSF Railway

rafer.nichols@bnsf.com

Office: (303) 480-6586

Cell: (817) 471-6614

DISCLAIMER:

BNSF has reviewed these plans and no exceptions are taken with regard to BNSF's ability to use the project as intended by your Engineers/Consultants. BNSF has not reviewed the design details or calculations for structural integrity or engineering accuracy. BNSF accepts no responsibility for errors or omissions in the design of the project.